

# NEW TOWN KOLKATA DEVELOPMENT AUTHORITY

(A Statutory Authority Under Government of West Bengal)  
3, Major Arterial Road, New Town, Kolkata - 700 156

Memo No: 550/EE(E)/NKDA/2019-20

Dated: 04/02/2019

## CORRIGENDUM-II

Name of Work: Illumination of Solar Street Light at the Pathway of Green Verge at AA-ID & AA-II New Town

Ref: Notice Inviting e-Quotation No.07/EE-E/NKDA/2019-20 Circulated vide Memo no. 213/NKDA/Elect/2019-20 dated: 14-01-2020.  
Tender ID: 2020\_NKDA\_265947\_1

This is to notify that due to some scanning error in the corrigendum-I, has been placed as corrigendum-II bellow:

Sl. No.	Query raised/suggestions placed by bidders in the pre bid meeting	Amended to
<b>NIeQ Point No. 5. Eligibility criteria for participation in the tender:</b>		
1	5-(VII)The prospective bidders in their full time engagement experienced Electrical Supervisor, having SCC Part of 1,2,3,4,11 or National (Authenticated documents in respect of qualification and Full time Employment through ECR copy of PF & ESI for engagement shall be furnished for Technical Evaluation.) (If Supervisor having above mentioned Part is being Proprietor/Partner/Director of Company then ECR copy may not required).	5-(VII)The prospective bidders engagement experienced Electrical Supervisor, having SCC Part of 1,2,4,11 or National (Authenticated documents in respect of qualification and Full time Employment through ECR copy of PF & ESI for engagement shall be furnished for Technical Evaluation.) (If Supervisor having above mentioned Part is being Proprietor/Partner/Director of Company then ECR copy may not required).
Technical Specification:		
2	<b>5. Mounting of light:</b> Pole height 5 m above the ground level. Luminaire shall be at least 4.5 m above the ground level. Foundation details of the 5 meter octagonal pole are attached sheet ,Base plate-200X200X12mm, Thickness : 3 mm, top dia-70 mm & bottom dia 130mm, Hot dip Galvanizing I minimum 80 mm	<b>5. Mounting of light:</b> Pole height 5 m above the ground level. Luminaire shall be at least 4.5 m above the ground level. Foundation details of the 5 meter octagonal pole are attached sheet ,Base plate-200X200X12mm, Thickness : 4 mm, top dia-70 mm & bottom dia 130mm, Hot dip Galvanizing I minimum 80 mm.
3	<b>7. Radiated Emission Test:</b> As per CISPR-15	As per OEM compliance along with CIRPS-15.

4	<b>12. <u>ESD (Electro Static Discharge) and Radiated susceptibility test:</u></b> As per IEC 61547	As per OEM compliance along with IEC 61547.
5	<b><u>MECHANICAL COMPONENTS:</u></b> VI. The battery shall be either included in the luminaire enclosure, which should be water proof (IP 65) and corrosion resistant or outside the luminaire enclosure in a vented, acid proof and corrosion resistant, hot dip galvanized metallic box (IP 65) with anti-theft locking arrangement for outdoor use.	<b><u>MECHANICAL COMPONENTS:</u></b> VI. The battery shall be either included in the luminaire enclosure, which should be water proof (IP 65) and corrosion resistant or outside the luminaire enclosure in a vented, acid proof and corrosion resistant, hot dip galvanized metallic box with water protected and anti-theft locking arrangement for outdoor use.

**Amended Date and Time Schedule: (Tender Document Point No14)**

Sl. No.	Particulars	Date & Time
3	Documents download end date (Online)	07-02-2020 upto 06:00 P.M
6	Bid submission closing date (Online)	07-02-2020 at 6:00 P.M
7	Bid opening date for Technical Proposals (Online)	10-02-2020 at 11:00 A.M.
8	Last Date of uploading list for Technically Qualified Bidder(online)	Will be intimated in due course.
9	Date for opening of Financial Proposal (Online).	Will be intimated in due course.

Other terms and conditions shall be remaining unchanged.


  
**Executive Engineer (E)**  
**New Town Kolkata Development Authority**

**Memo No: 550/(8)/EE(E)/NKDA/2019-20**

**Dated: 04/02/2020**

Copy forwarded for information to:-

- i. The Chief Executive Officer, New Town Kolkata Development Authority.
- ii. The Chief Executive Officer, New Town Kolkata Green Smart City Corporation Ltd.
- iii. The Chief Engineer, New Town Kolkata Development Authority.
- iv. The Finance Officer, New Town Kolkata Development Authority.
- v. The Assistant Engineer (E), New Town Kolkata Development Authority.
- vi. P.A to the Chairman, New Town Kolkata Development Authority.
- vii. Office copy of NKDA.
- viii. Official Website of New Town Kolkata Development Authority ([www.nkdamar.org](http://www.nkdamar.org))

  
**Executive Engineer (E)**  
**New Town Kolkata Development Authority**