



# NEW TOWN KOLKATA DEVELOPMENT AUTHORITY

(A Statutory Authority Under Government of West Bengal)  
3, Major Arterial Road, New Town, Kolkata - 700 156

Memo No : 4724/NKDA/Elect/01(CG Mkt)/Solar/2015

Date : 10<sup>th</sup> Aug 2015

## CORRIGENDUM

Sub : **Supply, Installation, Commissioning with five years comprehensive maintenance of 30 KWp Grid connected Solar PV power plant at rooftop of CG Community Market.**

Ref : Nlet No. 06 WBNKDA/SE(M/E)/NKDA/2015-16 vide Memo No. 4524/NKDA/ Elect/01(CG Mkt)/Solar/2015 date 31/07/2015.

This is to notify that due to typographical mistake and resolutions as taken in the Pre-Bid meeting held on 07<sup>th</sup> Aug 2015 at NKDA Conference hall, 01 MAR, New Town, Kolkata, few points are to be corrected or modified in the published in Nlet No. 06 WBNKDA/SE(M/E)/NKDA/2015-16 dated 31/07/2015 which are as follows :

1. "12 KWp Grid Connected Solar PV Power Plant" as written in the front page of Tender Document will be read as **"30 KWp Grid Connected Solar PV Power Plant."**
2. Last 2 (Two) Nos. Pages of the Technical Specification i.e. Clause No. 7.0 of Inverter panel and Schedule of work will be deleted.
3. In the Nlet Sl. No.5 part IV : "Must provide acceptable documents (list of skilled manpower and machinery) for its capacity to design, supply, installation, testing, commissioning and comprehensive maintenance of 30 KWp solar power plant or more within the given time schedule." will be read as : **"Tenderers should have credential of successful installation and completion of SPV of Capacity 20 KWp or more within last 3 (Three) years in a single Tender."**
4. In the Nlet Sl. No. No. 18 : "Income Tax & VAT will be deducted as per Govt. orders issued from time to time and would be applicable on the date of making payment of the bills. Building & other construction workers cess @ 1.0% will be deducted from progressive bills in pursuance with G.O. no. 599A/ 4M – 28 / 06 dated 27/09/2006." Will be read as **" All the payments will be made deducting Income Tax , VAT and other Taxes applicable as per Government Order(s) issued time to time and would be applicable on the date of making payment of the bills. Building & other construction workers cess @ 1.0% will be deducted from progressive bills in pursuance with G.O. no. 599A/ 4M – 28 / 06 dated 27/09/2006."**
5. In the Nlet Sl. No. No. 6 : Part I is to be included as " (i) **Materials will be stored at the working place for which security will be provided by the concern Executing agency only."**
6. In the Technical Specification Sl. No.6.0 Clause No.1.8 : "Hensel/Spelsberg/Ensto" will be read as **"Hensel/Spelsberg/Ensto or equivalent make (as per acceptability of NKDA)."**
7. In the Technical Specification Sl. No. 1.0 Clause No.1.3 : "The power from PV array shall be feed into grid through grid tied string inverter(s) of minimum nominal capacity 30 KW, 3Ø 415 V +/- 5% 50 Hz AC." Will be read as **"The power from PV array shall be feed into grid through grid tied string inverter(s) of 30 KW or more. Maximum 2 No. Inverters can be used for this purpose. Minimum nominal capacity of the grid tied string inverter(s) will be 30 KW, 3Ø 415 V +/- 10% 50 Hz AC."**



# NEW TOWN KOLKATA DEVELOPMENT AUTHORITY

(A Statutory Authority Under Government of West Bengal)  
3, Major Arterial Road, New Town, Kolkata - 700 156

02

8. In the Technical Specification Sl. No. 7.0 : "The power from PV array shall be feed into grid through grid tied string inverter(s) of minimum nominal capacity 30 KW, 3Ø 415 V +/- 5% 50 Hz AC." Will be read as **"The power from PV array shall be feed into grid through grid tied string inverter(s) of 30 KW or more. Maximum 2 No. Inverters can be used for this purpose. Minimum nominal capacity of the grid tied sting inverter(s) will be 30 KW, 3Ø 415 V +/- 10% 50 Hz AC."**
9. In the Technical Specification Sl. No. 7.0 Clause No.5.2 : "3Ø 415 V +/- 5% 50 Hz." will be read as **"3Ø 415 V +/- 10 % 50 Hz."**
10. In the Technical Specification Clause No. 7.0 Sl. No.5.4: "As per prevailing Grid Code. Note In case of voltage across the feeding point is found to deviated beyond the tolerable range as per grid code, the Inverter must have voltage adjusting feature of variation." will be read as **"As per prevailing Grid Code."**
11. In the Technical Specification Clause No. 9.0 : "One number 3Ø Import Energy meter of L&T" : The term "Import" will be read as **"Export."**

All other terms and conditions of the NleT shall remain unchanged.

*Para*  
10/08/15

Superintending Engineer (M/E)  
New town Kolkata Development Authority

Memo No : 4724/1(7)/NKDA/Elect/01(CG Mkt)/Solar/2015

Date : 10<sup>th</sup> Aug 2015

Copy Forwarded for information and necessary action to :

1. The Chief Executive Officer, New Town Kolkata Development Authority.
2. The Chief Engineer, New Town Kolkata Development Authority.
3. The Finance Officer, New Town Kolkata Development Authority.
4. The Estimator/ Sr. Accountant / Cashier, New Town Kolkata Development Authority.
5. PA to the Chairman, New Town Kolkata Development Authority.
6. Office Notice Board
7. Official Website of New Town Kolkata Development Authority. (www. nkdamar. Org)

Superintending Engineer (M/E)  
New town Kolkata Development Authority