



# NEW TOWN KOLKATA DEVELOPMENT AUTHORITY

(A Statutory Authority Under Government of West Bengal)  
3, Major Arterial Road, New Town, Kolkata - 700 156

Memo No: 5815/EE(E)/NKDA/2021

Dated: 25/06/2021

## CORRIGENDUM-III

**Name of Work: Conversion of conventional to LED street light at New Town under NKDA.**

Ref: I. Notice Inviting e-Quotation No.01/EE-E/NKDA/2021 Circulated vide memo no. 5406/NKDA/EE-E/2021 dated: 01-06-2021.

II. Tender ID: 2021\_NKDA\_332093\_1

This is to notify that due to typographical mistake and resolutions as taken few points are to be corrected or modified in the published in NleT No. 01/ EE-E/NKDA/Elect/2021 dated: 01-06-2021. which are as follow:

Sl. No.	In Tender document	Amended to
<b>NleQ Point No. 5. Eligibility criteria for participation in the tender:</b>		
1	5-(viii) The prospective bidders in their fulltime engagement experienced Electrical Supervisor, having SSC Part of 1,2,4,6A,7A,11 or National (Authenticated documents in respect of qualification and Full time Employment through ECR copy of PF & ESI for engagement shall be furnished for Technical Evaluation.) (If Supervisor having above mentioned Part is being Proprietor/Partner/Director of Company then ECR copy may not require).	5-(viii) The prospective bidders should have valid Electrical license declaration of Electrical Supervisor engaging in concurred agency through notary and his part holding at least 1, 2,4,6A,7A, & 11 with workman license certificate having sufficient part for mentioned work will have to be produced along with the originals. The original documents will be refunded after verification.
<b>Street light technical specification for both A and B:</b>		
4	<b>Driver:</b> LED driver should comply with 0 V to 10 V analog dimming for 0 -100% illumination level for the LED light fixture and also driver should comply for good dimming purpose.	<b>Driver:</b> LED driver should comply with 0 V to 10 V analog dimming for 0 -100% illumination level for the LED light fixture and also driver should comply for group dimming purpose.

Other terms and conditions shall be remaining unchanged.

Executive Engineer (E)

New Town Kolkata Development Authority

Memo No: 5851/(8)/EE(E)/NKDA/2021

Dated: 25/06/2021

Copy forwarded for information to:-

- The Chief Executive Officer, New Town Kolkata Development Authority.
- The Chief Executive Officer, New Town Kolkata Green Smart City Corporation Ltd.
- The Chief Engineer, New Town Kolkata Development Authority.
- The Finance Officer, New Town Kolkata Development Authority.
- The Assistant Engineer (E), New Town Kolkata Development Authority.
- P.A to the Chairman, New Town Kolkata Development Authority.
- Office copy of NKDA.
- Official Website of New Town Kolkata Development Authority ([www.nkdamar.org](http://www.nkdamar.org))

Executive Engineer (E)

New Town Kolkata Development Authority