

NEW TOWN KOLKATA DEVELOPMENT AUTHORITY


(A Statutory Authority Under Government of West Bengal)
Plot No. DG/13, Premises No. 04-3333, Action Area-ID,
New Town, Kolkata - 700 156

Meeting of the Committee to resolve issues involving tender criteria of Supply and delivery of different capacity switches, sockets, MCB's etc to the Electric Section of NKDA, Newtown Kolkata.







Date: 09.07.2025

Venue: Chief Engineer Conference Room of NKDA at 3rd Floor of NKDA Administrative Building
Minutes of the Meeting

Attendance of officials:

Sl. No.	Name	Designation	SIGNATURE
1	Shri Kalyan Roy Chowdhury	Chief Engineer, NKDA.	
2	Shri Tarit Paul	Superintending Engineer, NKDA	
3	Shri Binoy Kumar Mahato	Assistant Engineer (L&E), NKDA.	
4	Shri Tapan Kumar Sarkar	Junior Engineer (L&E), NKDA.	

Attendance of agencies:

Sl. No.	Name of Agency	SIGNATURE
1	Legrand	
2	Havells	
3	Schnider Electric	
4	PERFECT	
5	D.B. ENTERPRISE	
6	POWER POINT	
7	DEEP ENTERPRISE	
8	BEAUTY ENTERPRISE	

Discussion in the meeting are as follows:

SL NO	Queries by Agencies	Resolution
1	<u>Legrand:</u> <ul style="list-style-type: none"> a) Please specify fixed thermal and fixed magnetic/adjustable thermal and fixed magnetic of BOQ SL No.03 b) please specify 25/35 kA of BOQ SL No.03 c) If it is 25 kA or 35 kA. Icn = Ics = Ien = 100% to be mentioned d) 4-Pole e) To be fixed on DB as well as on panel f) 90° C inbuilt protection. 50° C authentic tap. 	<ul style="list-style-type: none"> a) Adjustable Thermal and magnetic. b) Breaking Capacity 35 KA c) ICS=100% from 35 KA and above d) 4 Pole MCB e) To be fixed on DB as well as on panel f) Inbuilt protection 90° C and ambient temperature 40° C

NEW TOWN KOLKATA DEVELOPMENT AUTHORITY

(A Statutory Authority Under Government of West Bengal)
Plot No. DG/13, Premises No. 04-3333, Action Area-ID,
New Town, Kolkata - 700 156

2	Havells: Requirement of spreader link in MCCB	Spreader link is required in MCCB
3	Schnider: a) Schnieder name to be included in the switch socket make b) BOQ SL No. 05, is it for MCCB? c) SL No. 06 of BOQ to be Clarified.	a) Not Allowed b) Yes c) Item is for SPNDB only
4	Deep Enterprise: a) Payment to be released within 1 (one) month of delivery. b) All materials to be taken by the department within 90 days from the issuing date of LOI	As per Tender
5	Power Point: Payment to be released within 15 days of delivery.	As per Tender
6	Beauty Enterprise: Warranty to be counted from the date of LOI issued.	As per Tender
7	Perfect: a) All materials to be taken by the department within 90 days from the issuing date of LOI b) Warranty to be applicable only for manufacturing defect cases.	As per Tender

S.E.E.

G.M./SE/NKDA

25/7/2025

Chief Engineer
New Town Kolkata Development Authority

Memo No. 6099 /1(8)/E-1106641/NKDA/CE/2025-26

Date: 25/7/2025

Forwarded for kind information and necessary action, please:

1. Chief Executive Officer, NKDA
2. Administrative Officer I&II, NKDA
3. Superintending Engineer, NKDA
4. Executive Engineer-E, NKDA
5. Finance Advisor, NKDA
6. Finance Officer, NKDA
7. Office Notice Board
8. Official website of NKDA.

25/7/2025

Chief Engineer
New Town Kolkata Development Authority